

November 03, 2016

Michael Anania  
NYS School for the Deaf  
401 Turin St  
Rome, NY 13440

RE: Project: NYSD - BLDG 11A/1st Floor  
Pace Project No.: 10366535

Dear Michael Anania:

Enclosed are the analytical results for sample(s) received by the laboratory on October 14, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards andple(s) 3-L4

---

---

---

---

### SAMPLE ANALYTE COUNT

Project: NYSD - BLDG 11A/1st Floor  
 Pace Project No.: 10366535

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
10366535001	Room 1-5/Bathroom	EPA 200.8	WBS	1	PASI-M
10366535002	Room 1-6/Office	EPA 200.8	WBS	1	PASI-M
10366535003	Room 1-14/Mens Bathroom	EPA 200.8	WBS	1	PASI-M
10366535004	Room 1-15/Womens Bathroom	EPA 200.8	WBS	1	PASI-M
10366535005	Room 1-19/ Lounge	EPA 200.8	WBS	1	PASI-M
10366535006	Room 1-20/Hallway Fountain	EPA 200.8	WBS	1	PASI-M
10366535007	Room 1-24/Mens Bathroom	EPA 200.8	WBS	1	PASI-M
10366535008	Room 1-26/Womens Bathroom/Left	EPA 200.8	WBS	1	PASI-M
10366535009	Room 1-26/WomensBathroom/Right	EPA 200.8	WBS	1	PASI-M
10366535010	Room 1-23	EPA 200.8	WBS	1	PASI-M

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: NYSD - BLDG 11A/1st Floor

Pace Project No.: 10366535

Sample: Room 1-5/Bathroom

Parameters

### ANALYTICAL RESULTS

Project: NYSD - BLDG 11A/1st Floor

Pace Project No.: 10366535

Sample: Room 1-24/Mens Bathroom	Lab ID: 10366535007	Collected: 10/08/16 00:01	Received: 10/14/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	8.0	ug/L	0.10	1	10/21/16 18:03	7439-92-1
------	-----	------	------	---	----------------	-----------

Sample: Room 1-26/Womens Bathroom/Left	Lab ID: 10366535008	Collected: 10/08/16 00:01	Received: 10/14/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	5.4	ug/L	0.10	1	10/21/16 18:04	7439-92-1
------	-----	------	------	---	----------------	-----------

Sample: Room 1-26/Womens Bathroom/Right	Lab ID: 10366535009	Collected: 10/08/16 00:02	Received: 10/14/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	3.2	ug/L	0.10	1	10/21/16 18:05	7439-92-1
------	-----	------	------	---	----------------	-----------

Sample: Room 1-23	Lab ID: 10366535010	Collected: 10/08/16 00:04	Received: 10/14/16 09:45	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS, DW Analytical Method: EPA 200.8

Lead	48.8	ug/L	0.10	1	10/21/16 18:06	7439-92-1
------	------	------	------	---	----------------	-----------

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: NYSD - BLDG 11A/1st Floor  
 Pace Project No.: 10366535

QC Batch: 442010 Analysis Method: EPA 200.8  
 QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water  
 Associated Lab Samples: 10366535001, 10366535002, 10366535003, 10366535004, 10366535005, 10366535006, 10366535007,  
 10366535008, 10366535009, 10366535010

METHOD BLANK: 2407294 Matrix: Water  
 Associated Lab Samples: 10366535001, 10366535002, 10366535003, 10366535004, 10366535005, 10366535006, 10366535007,  
 10366535008, 10366535009, 10366535010

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/21/16 17:48	

LABORATORY CONTROL SAMPLE: 2407295

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	98.9	99	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2411863 2411864

Parameter	Units	10366535001 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	333	100	100	446	428	114	96	70-130	4	20	

MATRIX SPIKE SAMPLE: 2411865

Parameter	Units	10366538001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L		1.8	100	108	107	70-130

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.

---



### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: NYSD - BLDG 11A/1st Floor  
Pace Project No.: 10366535

---

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
10366535001	Room 1-5/Bathroom	EPA 200.8	442010		
10366535002	Room 1-6/Office	EPA 200.8	442010		
10366535003	Room 1-14/Mens Bathroom	EPA 200.8	442010		
10366535004	Room 1-15/Womens Bathroom	EPA 200.8	442010		
10366535005	Room 1-19/ Lounge	EPA 200.8	442010		
10366535006	Room 1-20/Hallway Fountain	EPA 200.8	442010		
10366535007	Room 1-24/Mens Bathroom	EPA 200.8	442010		
10366535008	Room 1-26/Womens Bathroom/Left	EPA 200.8	442010		
10366535009	Room 1- 26/WomensBathroom/Right	EPA 200.8	442010		
10366535010	Room 1-23	EPA 200.8	442010		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,





temp ok

10/19/16