


Pace Analytical Services, LLC

1700 Elm Street - Suite 200

Minneapolis, MN 55414

(612)607-1700





ANALYTICAL RESULTS

Project: NYSD - BLDG.11B-2nd Floor

Pace Project No.: 10366511

| Sample: Room2-54/ Girls Bath/RightSink | | Lab ID: 10366511019 | Collected: 10/08/16 00:34 | Received: 10/14/16 09:45 | Matrix: Water | | | |
|--|---------|------------------------------|---------------------------|--------------------------|---------------|----------------|-----------|------|
| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
| 200.8 MET ICPMS, DW | | Analytical Method: EPA 200.8 | | | | | | |
| Lead | 67.7 | ug/L | 0.10 | 1 | | 10/22/16 13:24 | 7439-92-1 | |
| Sample: Room2-55/Boys Bath | | Lab ID: 10366511020 | Collected: 10/08/16 00:34 | Received: 10/14/16 09:45 | Matrix: Water | | | |
| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
| 200.8 MET ICPMS, DW | | Analytical Method: EPA 200.8 | | | | | | |
| Lead | 3.4 | ug/L | 0.10 | 1 | | 10/22/16 13:26 | 7439-92-1 | |
| Sample: Room2-57/Classroom/Left Sink | | Lab ID: 10366511021 | Collected: 10/08/16 00:30 | Received: 10/14/16 09:45 | Matrix: Water | | | |
| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
| 200.8 MET ICPMS, DW | | Analytical Method: EPA 200.8 | | | | | | |
| Lead | 1.6 | ug/L | 0.10 | 1 | | 10/20/16 13:25 | 7439-92-1 | |
| Sample: Room2-57/Classroom/Right Sink | | Lab ID: 10366511022 | Collected: 10/08/16 00:30 | Received: 10/14/16 09:45 | Matrix: Water | | | |
| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
| 200.8 MET ICPMS, DW | | Analytical Method: EPA 200.8 | | | | | | |
| Lead | 2.1 | ug/L | 0.10 | 1 | | 10/20/16 13:29 | 7439-92-1 | |
| Sample: Room2-58/ | | Lab ID: 10366511023 | | | | | | |
| Parameters | Results | Units | | | | | | |

ANALYTICAL RESULTS

Project: NYSD - BLDG.11B-2nd Floor

Pace Project No.: 10366511

| Sample: Room2-70/Hallway Fount./Lower | | Lab ID: 10366511031 | Collected: 10/08/16 00:55 | Received: 10/14/16 09:45 | Matrix: Water | | | |
|---------------------------------------|---------|------------------------------|---------------------------|--------------------------|---------------|----------------|-----------|------|
| Parameters | Results | Units | Report Limit | DF | Prepared | Analyzed | CAS No. | Qual |
| 200.8 MET ICPMS, DW | | Analytical Method: EPA 200.8 | | | | | | |
| Lead | 11.1 | ug/L | 0.10 | 1 | | 10/20/16 13:42 | 7439-92-1 | |

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: NYSD - BLDG.11B-2nd Floor

Pace Project No.: 10366511

QC Batch: 442005 Analysis Method: EPA 200.8
 QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
 Associated Lab Samples: 10366511001, 10366511002, 10366511003, 10366511004, 10366511005, 10366511006, 10366511007, 10366511008, 10366511009, 10366511010, 10366511011, 10366511012, 10366511013, 10366511014, 10366511015, 10366511016, 10366511017, 10366511018, 10366511019, 10366511020

METHOD BLANK: 2407271 Matrix: Water
 Associated Lab Samples: 10366511001, 10366511002, 10366511003, 10366511004, 10366511005, 10366511006, 10366511007, 10366511008, 10366511009, 10366511010, 10366511011, 10366511012, 10366511013, 10366511014, 10366511015, 10366511016, 10366511017, 10366511018, 10366511019, 10366511020

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|-----------|-------|--------------|-----------------|----------------|------------|
| Lead | ug/L | ND | 0.10 | 10/22/16 12:51 | |

LABORATORY CONTROL SAMPLE: 2407272

| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
|-----------|-------|-------------|------------|-----------|--------------|------------|
| Lead | ug/L | 100 | 99.5 | 99 | 85-115 | |

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2412656 2412657

| Parameter | Units | 10366511001 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual |
|-----------|-------|--------------------|----------------|-----------------|-----------|------------|----------|-----------|--------------|-----|---------|------|
| Lead | ug/L | 33.0 | 100 | 100 | 129 | 130 | 96 | 97 | 70-130 | 0 | 20 | |

MATRIX SPIKE SAMPLE: 2412658

| Parameter | Units | 10366511011 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers |
|-----------|-------|--------------------|-------------|-----------|----------|--------------|------------|
| Lead | ug/L | 4.0 | 100 | 105 | 101 | | |

QUALITY CONTROL DATA

Project: NYSD - BLDG.11B-2nd Floor

Pace Project No.: 10366511

| | | | |
|-------------------------|---|-----------------------|------------------------------|
| QC Batch: | 442170 | Analysis Method: | EPA 200.8 |
| QC Batch Method: | EPA 200.8 | Analysis Description: | ICPMS Metals, Drinking Water |
| Associated Lab Samples: | 10366511021, 10366511022, 10366511023, 10366511024, 10366511025, 10366511026, 10366511027, 10366511028, 10366511029, 10366511030, 10366511031 | | |

| | | | |
|-------------------------|---|---------|-------|
| METHOD BLANK: | 2409088 | Matrix: | Water |
| Associated Lab Samples: | 10366511021, 10366511022, 10366511023, 10366511024, 10366511025, 10366511026, 10366511027, 10366511028, 10366511029, 10366511030, 10366511031 | | |

| Parameter | Units | Blank Result | Reporting Limit | Analyzed | Qualifiers |
|-----------|-------|--------------|-----------------|----------------|------------|
| Lead | ug/L | ND | 0.10 | 10/20/16 13:23 | |

| LABORATORY CONTROL SAMPLE: 2409089 | | | | | | |
|------------------------------------|-------|-------------|------------|-----------|--------------|------------|
| Parameter | Units | Spike Conc. | LCS Result | LCS % Rec | % Rec Limits | Qualifiers |
| Lead | ug/L | 100 | 95.1 | 95 | 85-115 | |

| MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2409585 | | | | | | | | | | | | 2409586 | |
|--|-------|--------------------|----------------|-----------------|-----------|------------|----------|-----------|--------------|-----|---------|---------|--|
| Parameter | Units | 10366511021 Result | MS Spike Conc. | MSD Spike Conc. | MS Result | MSD Result | MS % Rec | MSD % Rec | % Rec Limits | RPD | Max RPD | Qual | |
| Lead | ug/L | 1.6 | 100 | 100 | 100 | 100 | 99 | 99 | 70-130 | 0 | 20 | | |

| MATRIX SPIKE SAMPLE: 2409587 | | | | | | | | | | | |
|------------------------------|-------|--------------------|-------------|-----------|----------|--------------|------------|--|--|--|--|
| Parameter | Units | 10366511031 Result | Spike Conc. | MS Result | MS % Rec | % Rec Limits | Qualifiers | | | | |
| Lead | ug/L | | 11.1 | 100 | 107 | 96 | 70-130 | | | | |

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project:
